

Client Code: CL-0002

Water Quality Report

Sample Code: WS1305-014

Customer:	Blessings Junior Primary School	
Sampling Location:	Blessings Junior Primary School	
Date, time of sampling:	08-May-2026	10:43:00 AM
Date, time of arrival at lab:	08-May-2026	3:16:00 PM
Date of completion:	09-May-2026	
Date Report Issued:	13-May-2026	
Volume in liters	0.5	Liters
Description:	Sensiblu System filtered solvent	

Results

(US EAS 2012: 2017 STANDARD FOR TREATED PORTABLE WATER)

Parameter	Code	Test Method	US EAS 12: 2017	Result	Units
pH value	P05	ISO 10523	6.5 - 8.5	7.1	1
Total Dissolved Solids	P04	ASTM D 5907	<700	93	mg/L
Salinity	P06	ISO 7888	<0.5	<1	ppt
Electric Conductivity	P01	ISO 7888	<1500	187	µS/cm
Total coliform	B01	ISO 9308	<1	<1	CFU per 100 mL
E. Coli	B02	ISO 9308	<1	<1	CFU per 100 mL
Total Plate Count at 37°C ml, Max	B03	ISO 6222	<50	<1	CFU/ml
Total Hardness (CaCO ₃)	C11	ISO 6059	<300	61	mg/L

Laboratory remarks

The water sample, **WS1305-014**, at "**Blessings Junior Primary School - Luwero**," was found to conform to the requirements of the **US EAS 12:2017 STANDARD FOR TREATED POTABLE WATER** for the parameters analyzed.

13/5/2026
Date



Sulman Muhanguzi
Laboratory Manager


Signature