

Client Code: CL-0002

Sample Code: WS1605-015

Water Quality Report

Customer:	GOD'S GRACE PRIMARY SCHOOL	
Sampling Location:	God's Grace Primary School	
Date, time of sampling:	13-May-2026	10:31:00 AM
Date, time of arrival at lab:	13-May-2026	4:16:00 PM
Date of completion:	15-May-2026	
Date Report Issued:	16-May-2026	
Volume in liters	0.5	Liters
Description:	Sensiblu System filtered solvent	

Results

(US EAS 2012: 2017 STANDARD FOR TREATED PORTABLE WATER)

Parameter	Code	Test Method	US EAS 12: 2017	Result	Units
pH value	P05	ISO 10523	6.5 - 8.5	6.9	1
Total Dissolved Solids	P04	ASTM D 5907	<700	319	mg/L
Salinity	P06	ISO 7888	<0.5	<1	ppt
Electric Conductivity	P01	ISO 7888	<1500	515	µS/cm
Total coliform	B01	ISO 9308	<1	<1	CFU per 100 mL
E. Coli	B02	ISO 9308	<1	<1	CFU per 100 mL
Total Plate Count at 37°C ml, Max	B03	ISO 6222	<50	<1	CFU/ml
Total Hardness (CaCO ₃)	C11	ISO 6059	<300	2.2	mg/L

Laboratory remarks

The water sample, **WS1605-015**, at "God's Grace Primary School - Luwero," was found to conform to the requirements of the **US EAS 12:2017 STANDARD FOR TREATED POTABLE WATER** for the parameters analyzed.

16/5/2026

Date

Sulman Muhanguzi

Laboratory Manager

Sulman Muhanguzi
Signature

