

Client Code: CL-0002

Sample Code: WS1506-022

Water Quality Report

Customer:	SENSIBLUE	
Sampling Location:	Sami Primary School -Mukono	
Date, time of sampling:	13 - June -2026	11.55:00 AM
Date, time of arrival at lab:	13 - June-2026	03.40: 00:00 PM
Date of completion:	15 – June - 2026	
Date Report Issued:	15 – June- 2026	
Volume in liters	0.5 Liter	
Description:	Filtered/treated water	

Results

(US EAS 2012: 2017 STANDARD FOR TREATED PORTABLE WATER)

Parameter	Code	Test Method	US EAS 12: 2017	Result	Units
pH value	P05	ISO 10523	6.5 - 8.5	7.48	1
Total Dissolved Solids	P04	ASTM D 5907	<700	101	mg/L
Conductivity	P01	ISO 7888	<1500	233	µS/cm
Turbidity	P03	ISO 7027	<5	<1	NTU
Color	P02	ISO 7887	<15	<1	TCU
Total coliform	B01	ISO 9308	<1	<1	CFU per 100 mL
E. Coli	B02	ISO 9308	<1	<1	CFU per 100 mL
Fluoride as F-	C03	ISO 10359	<1.5	0.09	mg/L
Nitrate	C04	ISO 7890	<45	1.02	mg/L
Magnesium	C05	ISO 7980	<100	11	mg/L
Iron MR	C08	ISO 6332	<0.3	<1	mg/L
Phosphates LR	C06	ISO 15681	<2.2	1.9	mg/L
Free chlorine	C10	ISO 7393	<0.5	0.03	mg/L
Total Hardness (CaCO3)	C11	ISO 6059	<300	22	mg/L
Sulphate	C12	ISO 22743	<400	2	mg/L

Laboratory remarks:

The water sample, **WS1506-022**, at “**Sami Primary School -Mukono**,” was found to conform to the requirements of the **US EAS 12:2017 STANDARD FOR TREATED POTABLE WATER** for all the parameters analyzed.

Handwritten signature: [Signature]

15/6/2026

Date



Sulman Muhanguzi

Laboratory Manager

Sulman Muhanguzi

Signature